CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1633:100 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Perfect Air Control Inc., 896 Rutherford Rd., Marion, NC 28752

Contact: Roger Engelke (828) 652-1424 FAX (828) 652-1729

DESIGN: Models 5000 fire rated dampers. Refer to listee's data sheet for detailed product description and

operational considerations. Models listed below:

	MOUNTING	RATING	SINGLE SIZE,In.		MULTIPLE SIZE, In.	
MODELS	POSITION	HOUR	W	Н	W	Н
*5000, 5010, 5015, 5020,	V	1 ½	36	45	120	84
5020-1	Н	1 ½	36	45	144	90
5050-1,-2, *-3	Н	1 ½	31	33	NA	NA
*5003, *5013, *5023,	V	3	30	30	NA	NA
*5023-1, *5053-1, *-2, *-3						
*5050G-1, *-2, *-3	V	1 ½	36	36	NA	NA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification, and UL label.

APPROVAL: Listed as fire rated dampers for use in heating, ventilating and air conditioning duct systems

passing through fire resistive walls and partitions. Refer to listee's Installation Instruction

Manual for details.

NOTE: 1. Leakage rating not evaluated. Refer to CSFM Listing No. 3230-1633:106 for leakage

rated dampers.

2. Formerly 3225-1518:100

*Rev. 05-17-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: APRIL 3, 2006 Listing Expires June 30, 2007

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager